

Certificate of Compliance

Certificate Number **270306 - S8301**
Report Reference **S8301, July 9th, 2003**
Issue Date **2006 March 27**

Page 1 of 2



Issued to: **Airsense Technology Ltd**

**Wilbury Way - 71 Knowl Piece
SG4 0TY Hitchin Hertfordshire United Kingdom**

*This is to certify that
representative samples of*

**Aspirating smoke detector, air sampling, laser
Model Airsense Stratos Micra 25.**

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

**UL 268 - Smoke-Automatic Fire Detectors
UL 268A - Smoke Detectors for Duct Application
CAN/ULC-S529 - Smoke Detectors for Fire Alarm Systems**

Additional Information:

See Addendum for Electrical Ratings

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: **Dan Michael**
Dan Michael, Project Engineer

Reviewed by: **John Tamas**
John Tamas, Senior Project Engineer

UL International (U.K.) Ltd.

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in United Kingdom, you may call +44 0 1483 302130.

Certificate of Compliance

Certificate Number **270306 - S8301**
Report Reference **S8301, July 9th, 2003**
Issue Date **2006 March 27**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL, cUL requirements.

Detector	Base	Normal Standby		Alarm	
		Voltage, V dc	Current, mA	Voltage, V dc	Alarm, mA
Stratos Micra 25	N/A	21.6 to 26.4	250	21.6 to 26.4	250

Issued by:

Dan Michael, Project Engineer

UL International (U.K.) Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (UK) Ltd.

Reviewed by:

John Tamas, Senior Project Engineer

UL International (U.K.) Ltd.